



CORRIGENDUM # 2

SUPPLY AND COMMISSIONING OF REMOTE MONITORING & CONTROL SYSTEM FOR AGCL GAS PIPELINE NETWORK PHASE-II

Tender doc. No.:
P.005712 R11050 001

Owner - Assam Gas Company Ltd. (AGCL)

Consultant - Tractebel Engineering Pvt. Ltd. (TEPL)

Date: 31.07.2018

Sr. No.	Description	Tender Page No.	Clause/ Para/ Section		Amendment/Addition/Modification/Deletion
Volume I of III- Commercial					
1	Details of Bid Documents- Bid Document fees (Non-refundable)	7 of 137	Clause no. 7.4 of IFB	Modification	Please read "Bid Document fees (Non-refundable)- Rs. 5,000.00 plus 18% GST i.e. Rs. 5,900.00"
2	Details of Bid Documents- Due date & time for submission of bid at e-tendering portal.	7 of 137 & Corrigendum # 1	Clause no. 7.6 of IFB & Corrigendum # 1	Modification	Please read "Due date & time for submission of bid at e-tendering portal. - Up to 1400 Hrs. IST on 27.08.2018"
3	Details of Bid Documents- Date & time of opening of Un-priced bids at AGCL Office at Duliajan, Dibrugarh, Assam	7 of 137 & Corrigendum # 1	Clause no. 7.7 of IFB & Corrigendum # 1	Modification	Please read "Date & time of opening of Un-priced bids at AGCL Office at Duliajan, Dibrugarh, Assam - At 1500 Hrs. IST on 27.08.2018"
4	Schedule of Rates	Schedule of Rates	Schedule of Rates	Modification	In view of the change in scope of work, bidders to consider quantities as below, Supply portion: SI no 6, Quantity 325 Service portion:SI no 6, Quantity 325 Accordingly, bidders price will be evaluated.
5	Schedule of Rates	Schedule of Rates	Schedule of Rates	Deletion	In view of the change in scope of work, bidders to quote price zero (0) against SOR SI. No. 15 of service portion.
6	Schedule of Rates	Schedule of Rates	Schedule of Rates	Modification	Please read as Supply, installation, commissioning of Office work Station at MCS with 21" monitor, key board, mouse and latest Operating system, microsoft office and antivirus Supply portion: SI no 14 Service portion:SI no 9
7	Schedule of Rates	Schedule of Rates	Schedule of Rates	Deletion	In view of the change in scope of work, bidders to quote price zero (0) against following SOR SI. No. Supply portion: Sr No 15 Service portion: Sr.No 10
8	Schedule of Rates	Schedule of Rates	Schedule of Rates	Deletion	In view of the change in scope of work, bidders to quote price zero (0) against following SOR SI. No. Supply portion: No Service portion: Sr.No 13
9	Schedule of Rates	Schedule of Rates	Schedule of Rates	Deletion	In view of the change in scope of work, bidders to quote price zero (0) against following SOR SI. No. Supply portion: No Service portion: Sr.No 16

SK Gupta
TE

TE

[Signature]



CORRIGENDUM # 2

SUPPLY AND COMMISSIONING OF REMOTE MONITORING & CONTROL SYSTEM FOR AGCL GAS PIPELINE NETWORK PHASE-II

Tender doc. No.:
P.005712 R11050 001

Owner - Assam Gas Company Ltd. (AGCL)

Consultant - Tractebel Engineering Pvt. Ltd. (TEPL)

Date: 31.07.2018

Sr. No.	Description	Tender Page No.	Clause/ Para/ Section	Amendment/Addition/Modification/Deletion	
Volume II of III- Technical					
10	Material Requisition-P.005712-I-11071-001 and	30 of 147	Item A(6)	Modification	Please read as Supply, installation /commissioning of moisture separator of 5 micron body material SS316, with drain valve, inlet and outlet sizing shall be as per site conditions Bidder shall read total quantity as 325 Nos
11	Material Requisition-P.005712-I-11071-001 and	31 of 147	Item A(20)	Deletion	Modification work for changing Tapping Point from downstream of FCV to upstream of FCV including supply of ½" SS316 tubing/fitting/valves and other materials as per the requirement at 74 locations of Naharkatia, Moran & Sonari area
12	Scope of work - P.005712-I-11075-001	50 of 147	Sr. No 7	Deletion	Modification of FCV tubing work
13	Material Requisition-P.005712-I-11071-001	31 of 147	Item A(14)	Modification	Please read as Supply, installation, commissioning of Office work Station at MCS with 21" monitor, key board, mouse and latest Operating system, microsoft office and antivirus
14	Scope of work - P.005712-I-11075-001	51 of 147	Sr. No 12	Modification	Please read as Supply, installation, commissioning of Office work Station at MCS with 21" monitor, key board, mouse and latest Operating system, microsoft office and antivirus
15	Material Requisition-P.005712-I-11071-001 and	31 of 147	Item A(15)	Deletion	Supply of 65" big screen at MCS and interface with existing SCADA system.
16	Material Requisition-P.005712-I-11071-001 and	31 of 147	Item A(18)	Deletion	Integration of 20 nos PRS EVC parameters with existing SCADA system through GSM network.
17	Scope of work - P.005712-I-11075-001	50 of 147	Sr. No 6	Deletion	Integration of PRS (Pressure Reducing Station) Parameters with AGCL's existing ABB SCADA through GSM Network
18	Material Requisition-P.005712-I-11071-001 and	32 of 147	Item A(21)	Deletion	Interfacing of all new 325 RTUs with existing ABB make SCADA system on DNP 3.0 (TCP/IP) protocol and APN based Airtel network.
19	Scope of work - P.005712-I-11075-001	50 of 147	Sr. No 5	Deletion	Integration of all new RTU parameters in existing SCADA system
20	Scope of work - P.005712-I-11075-001	51 of 147	Sr. No 13	Addition	New clause added, Bidder's scope of work shall inclusive of supply of single SIM with each dual SIM compatible modem from airtel or other service provider on Access Point Name (APN) technology, interface with RTU and show all the required field data in laptop at MCS in the presence of Existing SCADA OME and Owner/Owner's representative. Bidder's scope of work and responsibility to give all the required inputs to SCADA OEM and till all the field data satisfactory read/display is SCADA system (Configuration in SCADA system will be done by SCADA OEM) and support/assistance during integrated SAT.
21	Scope of work - P.005712-I-11075-001	51 of 147	Sr. No 14	Addition	New clause added, Bidder shall carryout RTU compatibility test with existing ABB make SCADA system on DNP 3.0 protocol and obtain the compatibility certificate from ABB. Only certified RTU shall be accepted. Bidder shall quote same make and model of RTU and enclosed compatibility certificate along with bid. Location of test will be informed to bidder. This test shall be carry out before 20-08-2018

Note: All other terms & conditions of tender document remain unaltered.

Signature
TE

Signature
TE

Signature