

Annexure I

Assam Gas Company Ltd., Duliajan

No. of DPNG connections upto October, 2021

District	Town	No. of DPNG connections
Dibrugarh	Duliajan	6936
	Naharkatia	869
	Dibrugarh	9384
	Moran	2824
Tinsukia	Tinsukia	4186
	Digboi	2948
	Margherita	1689
	Ledo	377
Jorhat	Jorhat	1430
	Titabar	157
	ONGC colony	479
Sivsagar	Sivasagar	4736
	Nazira	2337
Total existing DPNG connections		38352
No. of prospective new consumers		11648



ENERGISING QUALITY

CORRIGENDUM #2

Date: 03.12.2021

**ANNUAL RATE CONTRACT FOR PROCUREMENT OF
PREPAID GAS METERS**

Tender No : AGCL/GMB/PRE METDOM/ 2020/II/43 DTD. 09/11/2021



Sl. No.	Clause No.	Page No.	Description	Amendment/ Addition/ Modification/ Deletion	Details
1	POINT NOS. 50, 60 IN TECHNICAL QUERIES OF REPLY TO BIDDER'S PRE-BID QUERIES DATED 01.12.2021	-	3.2 Certification	Amendment	3.2 Certification is not required here, bidder to refer QAP attached in the tender document for inspection and test procedures.
2	POINT NOS. 55, 62, 69, 72 IN TECHNICAL QUERIES OF REPLY TO BIDDER'S PRE-BID QUERIES DATED 01.12.2021	-	M.A<0.62 mbar	Amendment	The overall Pressure loss should be as per EN 1359, which is ≤2mbar.
3	POINT NOS. 11 IN TECHNICAL QUERIES OF REPLY TO BIDDER'S PRE-BID QUERIES DATED 01.12.2021	-	3.1 DELIVERY LOCATION	Amendment	Bidder shall be responsible for transportation of meters to AGCL store near Duliajan, Assam. However, delivery from store to site shall be in client's scope.
Note:	1. All other terms and conditions of the tender documents shall remain unchanged. 2. Bidder to submit signed & stamped copy of this Corrigendum #2 along with Un-Price Bid				