

P. O. DULIAJAN  
DIST. DIBRUGARH  
ASSAM, PIN - 786 602

Tel : +91 0374 2800221, 2800582  
+91 0374 2800556, 2800558  
Fax : +91 0374 2800557  
e-mail : info@agclgas.com  
Visit us : www.assamgas.org



**ASSAM  
GAS COMPANY LTD**

(A GOVT. OF ASSAM UNDERTAKING)  
CIN : U11101AS1962SGC001184  
GSTIN : 18AABCA6977C1ZM

### CORRIGENDUM & ADDENDUM

- Ref: 1. Tender No.: C&P/RB/2025-26/01 dated: 27.01.2025  
2. Tender Name: Development of a New Retail Outlet at Naharkatia  
3. Tender ID: 2025\_ICD\_42376\_1  
4. Pre-Bid Meeting dated: 11.02.2025

The following corrigendum and addendum to the Tender Document are hereby issued.

#### CORRIGENDUM:


Sl. No. of BOQ	Item Description	Remarks
46	Supply, installation and commissioning of 15 KVA, three phase GENERATOR	The clause should be read as, <b>Supply, installation and commissioning of 15 KVA, three phase Diesel Generator (DG Set).</b>
55	Testing the tank hydro-statically with fresh water, to a pressure of 0.75 Kg/Sq.cm. (Testing includes supplying, filling and emptying out the water after testing) cleaning the internal surface of the tank etc. complete.	The clause should be read as, <b>Testing the tank hydro-statically with fresh water, to a pressure of 0.75 Kg/Sq.cm for 2 hours minimum holding period, with no drop-in pressure (Testing includes supplying, filling and emptying out the water after testing) cleaning the internal surface of the tank etc. complete.</b>
68.01	Supply, installation and calibration of pressure Gauges and their accessories inclusive of supply of necessary piping materials/tubings along with all necessary valves & fittings, fabrication and installation of impulse lines/manifolds as per AGCL standard Note: The quantities given above against individual items are indicative and shall not be considered to be binding. The quantities may increase or decrease at	Stands deleted. The bidder shall consider the quantity as "0" (zero) and amount to be quoted against the line item shall be "0" (zero). In case, it any bidder quotes a certain amount against the line item, then that amount shall be treated as "0" (zero) and evaluation shall be done accordingly.



	site at the time of actual execution and as per the discretion of Owner/ Engineer-in-charge. The unit rate shall be operated to work out the final payment due to Contractor.	
--	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--

**ADDENDUM:**

Sl. No. of BOQ	Item Description	Remarks
34.02	SLD (Single Line Diagram) of PDB (Power Distribution Board) for CNG facility	Drawing shall be uploaded in the tender portal.
36	Earth pit drawing & Electrode drawing	Drawing for Earth pit & Electrode shall be uploaded in the tender portal.

  
 12/02/2025  
 Engineer (C&P)  
 for Sr. Manager (C&P)-HoD,  
 Assam Gas Company Ltd.

**Sr. Manager (C&P) HoD**  
**Assam Gas Company Ltd.**  
 Duliajan