

P. O. DULIAJAN  
DIST. DIBRUGARH  
ASSAM, PIN - 786 602

Tel : +91 0374 2800221, 2800582  
+91 0374 2800556, 2800558  
Fax : +91 0374 2800557  
e-mail : info@agclgas.com  
Visit us : www.assamgas.org



**ASSAM  
GAS COMPANY LTD**

(A GOVT. OF ASSAM UNDERTAKING)  
CIN : U11101AS1962SGC001184  
GSTIN : 18AABCA6977C1ZM

### Reply to Pre-Bid Queries

- Ref: 1. Tender No.: C&P/RB/2025-26/01 dated: 27.01.2025  
2. Tender Name: Development of a New Retail Outlet at Naharkatia  
3. Tender ID: 2025\_ICD\_42376\_1  
4. Pre-Bid Meeting dated: 11.02.2025

**Query No. 1:** Exact location of the site.

**Our Reply:** Latitude: 27°17'56.11"N, Longitude: 95°18'45.82"E

**Query No. 2:** Earth Pit & chamber drawing.

**Our Reply:** Chamber Drawings attached along with the tender document. Earth pit drawing & Electrode drawing will be uploaded.

**Query No. 3:** Office Location for qualifying BEC/BRC of the tender.

**Our Reply:** The bidders should have their registered office or branch office in any of the following district of Assam: Dibrugarh/Tinsukia/Sibsagar. Documents to be submitted as proof are GST registration certificate /Trade licence/Electricity Bill/Telephone Bill/Property Tax or Water Tax paid receipt/ Bank Statement in the name of firm showing office address.

**Query No. 4:** Pressure Gauge at BOQ Sl. No. 68.01

**Our Reply:** Item at Sl. No. 68.01 (Pressure Gauge) stands deleted and a Corrigendum shall be uploaded against the same.

**Query No. 5:** Specifications for Hydro-Testing on UST.

**Our Reply:** Tank hydro-testing to be done at 0.75 kg/cm<sup>2</sup> pressure for 2 hours minimum holding period, with no drop-in pressure. A Corrigendum shall be uploaded against the same.

**Query No. 6:** BOQ Sl. No.:46; i.e. Supply, installation and commissioning of 15 KVA, three phase GENERATOR.

**Our Reply:** The Generator mentioned in BOQ Sl. No.:46 shall be a Diesel Generator (DG Set). A Corrigendum shall be uploaded against the same.

**Query No. 7:** BOQ Sl. No.: 34.02; SLD (Single Line Diagram) of PDB (Power Distribution Board) for CNG facility.




**Our Reply:** SLD of PDB for CNG facility will be uploaded.

**Query No. 8:** Requirement of separate line item for sliding of earth during excavation.

**Our Reply:** There is no separate line item for sliding of earth during excavation; the bidder shall consider the cost within excavation as per BOQ SI. No. 5.01

**Query No. 9:** Requirement of separate line item for excavation up to 1.5 m depth.

**Our Reply:** There is no separate line item for excavation up to 1.5 m depth. The bidder shall refer BOQ SI. No. 5.01

for  12/02/2025  
Engineer (C&P)  
Sr. Manager (C&P)-HoD,  
Assam Gas Company Ltd.

**Sr. Manager (C&P) HoD  
Assam Gas Company Ltd.  
Duliajan**