



REPLY TO BIDDER'S PRE-BID QUERIES-2
PROCUREMENT OF FIRE AND GAS SYSTEMS
FOR
NAMBOR – GOLAGHAT- NUMALIGARH AREA GAS PIPELINE PROJECT
Tender No : AGCL/BD/PMC-GHT/F&G/2020/158 dated 16/11/2022



Sr. No.	Tender Clause No. / Annexures	Page No	Clause No	Subject	Bidders Comments / Queries	VCS Reply
1	1009-00-IN-SOW-5004 Scope of Work for F&G sytem	Page 8 of 13	5.1	I/O redundancy of 25% is to be maintained	Full triplicate redundancy is asked as per DOCNO: VCS-SS-IN-5905 section 4.2 so what is meaning for I/O redundancy of 25%	Vendors shall be required to maintain the 25% spare I/O of the considered redundant I/O in the F&G system panel.
2	DOCNO: VCS-SS-IN-5905 Section 4.2.4	Page 8 of 15	4.2.4	Digital output	Triplicate redundancy for digital output is required or not like mentioned in case of digital input and analog inputs	As per tender spec. triplicate redundancy for Digital Output is not required.
3	-	-	-	-	GAIL (India) Limited is Indias largest natural gas company and operates with a very efficient and safe safety system all across their locations throughout India. As Assam gas company is in similar business we request startup exemption for the above referred tender in line with the exemption granted by M/S GAIL (India) Limited.	Tender conditions shall prevail.

NOTE:
Bidder to submit signed & stamped copy of this Reply to Pre-Bid Queries-2 along with Un-Price Bid.