



CORRIGENDUM #6
PROCUREMENT OF FIRE AND GAS SYSTEM
Tender No: AGCL/BD/PMC-GHT/F&G/2020/20 DATED 28/02/2020

Date: 13.05.2020



Sl. No.	Clause No.	Page No.	Description	Amendment/ Addition/ Modification/ Deletion	Details
1	Corrigendum #3 S. No.4	-	7.2) 20% value shall be paid pro-rata on completion of Erection at individual station and on submission Certification for completion of Erection, issued by Purchaser/ Engineer – In -Charge / representative at site.	Modification	Clause No.7.2 of Corrigendum #3 (Sl. No 4) may be read as : 20% value shall be paid pro-rata on completion of Erection at individual station and on submission Certification for completion of Erection, issued by Purchaser/ Engineer – In -Charge / representative at site. If, erection is not started within 90 days after supply due to non-availability of site, payment against erection shall be released to the successful bidder against receipt of bank guarantee of the equivalent amount to initially remain valid for a period of 1 year after completion of 90 days; i.e; 15 months from the date of FOT site (actual) & shall be extended further, if required.
			7.3) 10% value shall be paid on successful Site Acceptance Testing, Trial run, overall commissioning and on submission of Certification for completion of successful SAT, Trial, overall commissioning issued by Engineer – in -Charge / representative at site.		Clause No.7.3 of Corrigendum #3 (Sl. No 4) may be read as : 10% value shall be paid on successful Site Acceptance Testing, Trial run, overall commissioning and on submission of Certification for completion of successful SAT, Trial, overall commissioning issued by Engineer – in -Charge / representative at site. In case the commissioning cannot be completed within 90 days due to non availability of site, payment against commissioning shall be released to the successful bidder against receipt of bank guarantee of the equivalent amount to initially remain valid for a period of 1 year after completion of 90 days; i.e; 15 months from the date of FOT site (actual) & shall be extended further, if required.
			7.4) 10% of supply value on completion of all works including final acceptance, Handing over and submission of Certification for completion of all works including final acceptance, All documents as specified in tender document; Submission of "As built drawing/ documents" and handing over issued by Purchaser/Consultant/ / Engineer – In -Charge (EIC) / representative at site.		Clause No.7.4 of Corrigendum #3 (Sl. No 4) may be read as : 10% of supply value on completion of all works including final acceptance, Handing over and submission of Certification for completion of all works including final acceptance, All documents as specified in tender document; Submission of "As built drawing/ documents" and handing over issued by Purchaser/Consultant/ / Engineer – In -Charge (EIC) / representative at site. In case the final acceptance cannot be completed due to non availability of site, the payment shall be released to the successful bidder against receipt of bank guarantee of the equivalent amount to initially remain valid for a period of 1 year after completion of 90 days; i.e; 15 months from the date of FOT site (actual) & shall be extended further, if required.
2	REPLY TO BIDDER'S PRE-BID QUERIES -2 S. No. 13	-	I/O LIST - F&G SYSTEM	Modification	VCS/ AGCL's 'REPLIES TO BIDDER'S PRE BID QUERY -2' at Sl. No. 13 stands deleted. Modified Reply to S. No. 13 of 'REPLIES TO BIDDER'S PRE BID QUERY -2' The Point gas detector and Open path gas detector shall be NIS type in I/O list - F&G SYSTEM; document no.: 1009-00-IN-LST-5001 of technical tender document.
NOTE :					
1	All other terms and conditions of the tender shall remain unchanged.				
2	This Corrigendum #6 is an integral part of the tender. Bidder to submit signed and stamped copy of this document along with unprice Bid.				