

No: MTL/PUR/213/ELECT/2018-19/03

Date : 11/10/2018

To

Type of Bid : LIMITED TENDER  
Bidding type : Single Bid  
Bid Closing on : 25/10/2018 (2.00 P.M.)  
Bid Opening on : 25/10/2018 (2.30 P.M.)  
EMD : As per Annexure-I

ASSAM GAS COMPANY LIMITED invites Limited tenders for supply of following items and Technical Specification given at Annexure-II.

Sl No.	Item Code	Item Description	Unit	Qty
01	03034744	LED Flood Light 150 W <b>Make :</b> HAVELLS/HPL/PHILLIPS/CROMPTRON GREAVES/BAJAJ	No	06
02	New Item	LED Flood Light 50 W <b>Make :</b> Havells/HPL/PHILLIPS/CROMPTRON GREAVES/BAJAJ	No	06

**Terms & Conditions for Limited Tenders :**

1. The bidder should quote their rates with applicable taxes etc. as per the FORMAT given below :

Item No.	Materials Description	Unit	Rate/ Unit (INR)	GST @ %	Freight	Amount/unit INR ( FOR Duliajan)	Quantity	Total Amount (INR)
			(A)	(B)	(C)	(A)+(B)+(C)=D	(E)	(D) X( E)

2. The TOTAL AMOUNT shall be in figure as well as in words. No overwriting shall be allowed. In case of discrepancy, the rates quoted in words shall be considered to be correct.
3. Sealed envelope containing the bid duly filled in as per above Format on bidders letter head should reach Sr. Manager (Materials)-HOD, Assam Gas Company Limited, Duliajan-786602, Dist. Dibrugarh (Assam) on or before the bid closing date and time as mentioned above. If the bid closing date happens to be holiday/bandh called than the next full working day will be considered as bid closing date.

4. The Sealed envelope containing the bid shall be marked at the top of the envelope with following information.
  - a) AGCL Tender No.
  - b) Bid Closing date
  - c) Bidder's Name
  - d) Brief description of supply

The bid received without mention of above on the envelope shall not be accepted.

5. Bid received vide E-mail/Fax/Telegram/Telegram/Telex/Cable/ bid in open condition will not be accepted.
6. The company will not be responsible for any postal delay or non-receipt.
7. **Validity** : The bid must be valid for 90 (Ninety ) days from the date of opening of the bid.
8. **Delivery** : The ordered materials shall be delivered within 15 (Fifteen) days from the date of receipt of the Purchase Order by Fax/E-mail etc. at AGCL's store, Duliajan. Bid offer with FOR other than AGCL's store, Duliajan shall be rejected outright and shall not be considered for evaluation.
9. **Liquidated Damage** : The completion of delivery of the entire quantities as mentioned above within the schedule date of completion of delivery shall be deemed to be the essence of the contract. In case of delay in delivery of the entire quantities within the stipulated period, unless such delay is attributable to the owner (AGCL) or due to Force Majeure condition, there will be reduction in contract value @ 0. 5% (Zero Point Five percent) for undelivered quantities of materials for each week of delay or part thereof subject to maximum of 5% of the total contract value as Liquidated Damage. The L. D charge shall be recovered from the supplier's bill / invoice.
10. **Payment** : 100% (Hundred percent) Payment shall be made to the supplier within 30 (thirty) days after receipt and acceptance of materials against submission of original invoice in triplicate.
11. Conditional bids are liable to rejection at the sole discretion of the Company.
12. **Guarantee/Warrantee** : Guarantee/Warrantee shall stand as per Manufacturer Certificate. Guarantee should be survived for minimum 36 (Thirty Six) months for fittings & 60 (Sixty) month for LED Bulb. The eligible vendor shall furnish certificate of Warranty along with materials delivery.

13. **Applicability of Law & Jurisdiction** : The Order shall be governed and interpreted in accordance with the applicable laws of India and Dibrugarh Court in the State of Assam shall have exclusive jurisdiction.
14. The Company reserves the right of rejecting any or all bids, accepting any bid in part, without assigning any reason.

Thanking You,

Yours faithfully,

For and on behalf of **MANAGING DIRECTOR**

ASSAM GAS COMPANY LIMITED  
( A Govt.of Assam Undertaking )  
P.O.Duliajan – 786 602 Assam  
E-mail : agcmat2@gmail.com

ANNEXURE – I  
EARNEST MONEY DEPOSIT : (EMD)  
For Limited Tenders only  
EMD to be deposited by the bidder is as follows:

<u>ESTIMATE TOTAL VALUE ( Rs.)</u>		<u>EMD ( Rs.)</u>
Upto	50,000	NIL
50,001 to	1,00,000	2000.00
1,00,001 to	2,00,000	4000.00
2,00,001 to	5,00,000	10,000.00
5,00,001 to	10,00,000	20,000.00
10,00,001 to	25,00,000 & above	50,000.00

## **Annexure-II**

### **Technical Specification of the tendered items**

**Ref. NIT No. MTL/PUR/213/ELECT/2018-19/03 dtd. 11/10/2018**

#### **LED Flood Light 150 W Fitting with Bulb**

**Housing** : High grade Aluminium pressure Die-cast with efficient heat dissipation design. It must be sturdy and corrosion resistant.

**Cover** : Toughened Glass

**IP** : IP65

**LED Bulb Make** : Osram/Cree/Nichia/Seoul/Samsung or equivalent

**LED Efficacy** :  $\geq 150$  lumen/watt

**Optics** : High speed using high quality lenses & reflector, wide beam angle more than  $120^\circ$

**System Management** : Multiple LEDs must be used in series-parallel array.

**Control Gear** : Built in, replaceable electronic driver with APFC and control driver with efficiency  $> 85\%$

**Special Features** : Over voltage protection up to 300V, Surge protection of at least 4KV, Isolation up to 1.5KV

**IP Rating** : IP66

**Installation** : Mounting bracket having at least three number of holes provided along with the luminaire.

Fixture & LED lamp conforms to LM-79 & LM-80 respectively

**Input voltage range** : 150-270 V / 50Hz

**Power Factor** :  $\geq 0.95$

**Colour Rendering Index**:  $\geq 70$

**Operating Temperature** : 0 to  $50^\circ\text{C}$

**Colour Temperature** : 5700 K  $\pm$  500 K

**Warranty fittings :** At least 3 yrs.

**Waranty LED lamp :** At least 5 yrs.

**Preferred Make of Entire Fitting :** HAVELLS/HPL/PHILLIPS/CROMPTRON  
GREAVES/BAJAJ.

### **LED Flood Light 50 W Fitting with Bulb**

**Housing :** High grade Aluminium pressure Die-cast with efficient heat dissipation design. It must be sturdy and corrosion resistant.

**Cover :** Toughened Glass

**IP :** IP65

**LED Bulb Make :** Osram/Cree/Nichia/Seoul/Samsung or equivalent

**LED Efficacy :**  $\geq 50$  lumen/watt

**Optics :** High speed using high quality lenses & reflector, wide beam angle more than  $120^\circ$

**System Management :** Multiple LEDs must be used in series-parallel array.

**Control Gear :** Built in, replaceable electronic driver with APFC and control driver with efficiency  $> 85\%$

**Special Features :** Over voltage protection up to 300V, Surge protection of at least 4KV, Isolation up to 1.5KV

**IP Rating :** IP66

**Installation :** Mounting bracket having atleast three number of holes provided along with the luminaire.

Fixture & LED lamp conforms to LM-79 & LM-80 respectively

**Input voltage range :** 150-270 V / 50Hz

**Power Factor :**  $\geq 0.95$

**Colour Rendering Index:**  $\geq 70$

**Operating Temperature :** 0 to  $50^\circ\text{C}$

**Colour Temperature :** 5700 K  $\pm 500$  K

**Warranty fittings :** At least 3 yrs.

**Waranty LED lamp :** At least 5 yrs.

**Preferred Make of Entire Fitting :** HAVELLS/HPL/PHILLIPS/CROMPTRON  
GREAVES/BAJAJ.